



## University of Pittsburgh

### Old Engineering Hall

3943 O'Hara Street

### Occupant Information

This information is for occupants of Old Engineering Hall. University guidelines for workplace safety, emergency preparedness and emergency response are found in the University of Pittsburgh Safety Manual <https://www.ehs.pitt.edu/manual> and the University of Pittsburgh Emergency Management Guidelines found on <https://www.emergency.pitt.edu/resources/emergency-management-guidelines>.

In the event of a fire in Old Engineering Hall, the entire building will signal fire alarm conditions. *If the fire alarm signal (visual strobe lights and audible horns) activates; **evacuate the building**.* The fire alarm pull stations are located at the exit doors and near the stairwells.

**1. If you hear or observe the fire alarm signal:**

- i. If possible and safe to do so: turn off gas, hot plates, and other ignition sources. Close fume hood sash.
- ii. Close the door behind you and evacuate the building by following the EXIT signs to nearest stairwell or exterior door. Do not use the elevators during an alarm condition, unless directed by an emergency responder.
- iii. Proceed to an assembly point away from the building. The closest assembly area for Old Engineering Hall is Benedum Hall at 3700 O'Hara Street.
- iv. Do not re-enter any until the "all clear" signal is given by the police or fire department.

2. **Upon discovery of smoke or fire:**

- i. Alert anyone in immediate danger.
- ii. Close the door to contain smoke or fire.
- iii. Activate the nearest pull station.**
- iv. Evacuate the building.

Note: If you cannot activate the pull station and you are in a safe area, call 911 or call University Police at 412-624-2121.

2. **Evacuation Plan**

Evacuate using the nearest stairwell upon any activation of the emergency alarm on your floor. For general information on evacuation, visit the [Safe Building Evacuation](#) under the Fire Safety section of the EH&S website. In the event of a prolonged evacuation or extreme weather conditions, a short-term assembly site will be opened. The short-term assembly area for occupants of Old Engineering Hall is Benedum Hall. In the event of a major emergency, the long-term assembly area for Old Engineering Hall occupants is the Petersen Events Center. If sheltering is necessary, you will be informed by University representatives to proceed to either of these sites.

If you cannot follow the University's Building Evacuation Procedures due to a temporary or permanent physical impairment, please contact Pitt EH&S 412-624-9505 and request development of an Individualized Evacuation Plan.

**Evacuation routes**

**Floors 7-4** - Exit using Stairwell B, down to floor 1 and egress through the main entrance/exit onto O'Hara Street,  
Or,  
Exit using Stairwell D, down to floor 4 and egress onto Dammond Drive.

**Floor 3** - Exit using Stairwell B, down to floor 1 and egress through the main entrance/exit onto O'Hara Street,  
Or,  
Exit using Stairwell C, down to floor B and egress onto O'Hara Street,  
Or,  
Exit using Stairwell D, up to stairwell landing between floors 3 and 4, then egress onto Dammond Drive.

**Floor 2** - Exit using Stairwell B, down to floor 1 and egress through the main entrance/exit onto O'Hara Street,  
Or,  
Exit using Stairwell C, down to floor B and egress onto O'Hara Street,  
Or,  
Exit using Stairwell A, down to floor 1 and egress onto O'Hara Street,  
Or,  
Exit southwest towards Van De Graaf (NPL) Building and egress onto floor 2 of Van De Graaf Building,

**Floor 1** - Exit using Stairwell A and egress onto O’Hara Street,  
Or,  
Exit using Stairwell B and egress through the main entrance/exit onto O’Hara Street,  
Or,  
Exit using Stairwell C, down to floor B and egress onto O’Hara Street,  
Or,  
Exit southwest towards Van De Graaf (NPL) Building and egress onto floor 1 of Van De Graaf Building,  
Or,  
Exit using the northeast building exit and egress onto Dammond Drive.

**Basement** - Exit using Stairwell C and egress onto O’Hara Street,  
Or,  
Exit using Stairwell A, up to floor 1 and egress onto O’Hara St,  
Or,  
Exit using Stairwell B, up to floor 1 and egress through the main entrance/exit onto O’Hara Street,

4. **Medical Emergency:** Call Pitt Police at 412-624-2121

5. **Security Emergency:** Call Pitt Police at 412-624-2121.

Old Engineering Hall is equipped for remote activation of an emergency alarm by the University Police. One of two messages can be remotely activated. An emergency evacuation for security purposes that states “May I have your attention please. A security alert has been reported. Please leave the building by the nearest exit. Do not use the elevators.”; or a shelter-in-place announcement that states: “May I have your attention please. A security emergency has been reported. Remain in the building. Stand by for further instructions.” Both messages are accompanied by the activation of strobe lights.

6. **Building Utility Emergency**

For any utility emergency or utility problem (including electrical, water, heating, air conditioning, elevator), contact Facilities Management at 412-624-9500. In the event of a power failure, emergency generators will supply power to emergency lighting, critical equipment and every red receptacle.

7. **Building Entry Procedures**

**Old Engineering Hall operation hours are:**

Monday-Friday:           7:00am - 10:00pm

Do not enter Old Engineering Hall or any campus building if you note that the building’s emergency alarm is signaling, or that the building has been posted with signs that indicate an on-going emergency alarm condition.

## 8. Chemicals

- i. Chemical Spills: If assistance is required with a chemical spill or release, contact Pitt EH&S 412-624-9505. For spills that have potential for fire or health hazard, evacuate and secure the area. Then call the University emergency number 412-624-2121 from a safe location.
- ii. Relocating/Moving Chemicals: Secondary containment must be used when moving/relocating chemicals from your floor. If chemicals will be moved over public roadways, contact Pitt EH&S 412-624-9505 two weeks in advance for direction and assistance with DOT regulations and other chemical handling requirements.
- iii. Chemical Waste Disposal:

**Old Engineering Hall Chemical Waste Disposal:** Lab staff transports chemical waste to the Waste Storage Vault on the Old Engineering Hall Loading Dock every other Friday. See [EH&S - Chemical Waste Disposal web page](#) for more information on chemical waste disposal.

- iv. All chemical waste must be identified and labeled appropriately with an orange chemical waste label supplied by the University. Secondary containment must be used when transporting chemicals and chemical waste through the building. Never abandon chemical waste in corridors or on the loading dock.

## 9. Biological Materials

- i. Biological Spill: If assistance is required for a small biological spill or release, contact Pitt EH&S 412-624-9505. For large spills, evacuate and secure the area. Then call the University emergency number 412-624-2121 from a safe location.
- ii. Moving Biological Materials to another floor or building
  - a. Place material in **leak-proof primary receptacles** (sealed/stoppered vials, screw-on, or snap-on lids or caps).
  - b. Primary receptacles should be placed in a **leak-proof secondary container** such as sealed plastic bags or sealed containers.
  - c. **Absorbent material** (e.g. paper towels) should be placed between the primary and secondary receptacles in sufficient quantity to absorb the contents.
  - d. A **rigid outer package**, such as a cardboard box or foam container should be used to transport the primary and secondary receptacles.
  - e. **Labeling** of the material to identify the contents and the 'owner' should be placed on the primary or secondary container.
- iii. Biological Waste Disposal:

**Old Engineering Hall Biological Waste Disposal:** Decontaminate all materials and discard in red-bag-lined biohazard box within the lab. Seal the box and take the box to the Waste Storage Vault on Old Engineering Hall's loading dock. See [EH&S website for Biological Waste Disposal](#) for additional details.

- iv. Sharps: All sharps must be disposed in sharps containers. When 2/3 full, sharps containers must be sealed and separated from other bio hazardous waste. Use a separate biohazard box labeled “sharps.” Multiple sharps containers may be discarded in one labeled biohazard box.

#### **10. Radiation Incidents**

In the event of an emergency or incident involving ionizing radiation sources, contact the Radiation Safety Office at 412-624-2728.

#### **11. Removal and discarding of lab and office equipment**

- i. Before removing any equipment from your lab or office, please refer to the EH&S site for proper procedures: [Moving Equipment from Biological Labs](#).
- ii. Never leave equipment in the hallways or on the outside loading dock.
- iii. All lab equipment must have a signed Laboratory Equipment Decontamination Certificate attached to each piece of equipment before Surplus Property will pick up.

#### **Important Phone Numbers**

Pittsburgh Campus Emergency	412-624-2121
Pitt Police	412-624-2121
Facilities Management	412-624-9500
Environmental Health and Safety	412-624-9505